

**Addendum
No. 2**

Date: October 7, 2019

Project: Delaware Technical and Community College
Owens Campus – Carter Center – Operable Panel Partition Replacement
Contract No. DTCC C900402CFW

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

General

1. PDF files for drawings and specs will be made available upon request.
2. Additional visits to the site can be arranged by contacting the facilities office at the following number:

302-259-6210

RFI Responses

1. ***Will this project be buy America?***

There are no Buy America requirements on this project.

2. ***Will there be any sprinkler, electrical or mechanical work involved due to remove of acoustical ceiling and new sound walls?***

Ceiling mounted fixtures, devices and equipment in areas where ceiling is removed must be supported and reinstalled by the contractor.

There are existing building systems which pass over the movable partitions and through the new sound walls, including, but not limited to ductwork, electrical conduit, data wiring, and sprinkler piping. New construction must accommodate the existing building systems and all penetrations must be sealed.

Contractor shall review field conditions for this work prior to submitting bid.

End